

EC CERTIFICATE OF CONFORMITY

359-CPD-0010

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Xpander Class A1R Heat Detector Head XPA-HT-11170-APO

placed on the market by

Apollo Fire Detectors Limited, 36 Brookside Road, Havant, Hampshire, PO9 1JR

and produced in the factory by

Apollo Fire Detectors Limited, 36 Brookside Road, Havant, Hampshire, PO9 1JR

Is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body No. **359 - Intertek Testing & Certification Ltd** – has performed the initial type- testing for the relevant characteristics of the product, the initial inspection of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the product performance described in Annex ZA of the product standards

EN54-5:2000 + A1:2002

- Fire detection and fire alarm systems - Heat detectors - Point detectors

were applied and that the product fulfils all the prescribed requirements.

This certification was issued on **16 March 2010** and remains valid as long as the conditions laid down in the harmonised technical specification above, or the product design, or the manufacturing conditions in the factory, or the FPC itself are not modified significantly and latest on **16 March 2015**.



Jerry Quayle
Director



Intertek Testing & Certification Ltd
Intertek House, Cleeve Road,
Leatherhead, Surrey, KT22 7SB
United Kingdom

Phone : +44 (0) 1372 370900
Fax : +44 (0) 1372 370999
E-mail: cpd.uk@intertek.com

Appendix to EC Certificate of conformity 359-CPD-0010

The details and condition of use for the Xpander Class A1R Heat Detector Head XPA-HT-11170-APO, placed on the market by Apollo Fire Detectors Limited are:

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Bases:

Xpander Wireless Detector Base XPA-WB-10022-APO*

*Base manufactured by EMS Security Group Limited.

General Notes:

1. The device must be used with the following batteries only:
MN1500 LR6-1.5 volt alkaline AA cells
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

This certification was issued on **16 March 2010** and remains valid as long as the conditions laid down in the harmonised technical specification above, or the product design, or the manufacturing conditions in the factory, or the FPC itself are not modified significantly and latest on **16 March 2015**.



Jerry Quayle
Director